

Vacuum Contactor Retrofit

REYROLLE S14A

OVERVIEW

- Type tested retrofit
- Long life
- Low maintenance
- Long term service support
sing Allenwest-Wallacetown
type CHV30 VCB
- Enhanced performance ratings



TECHNICAL DATA	<i>P&B Type tested rating</i>
SYSTEM VOLTS	3.3 kV
RATED CURRENT	300 A
FREQUENCY	50 / 60 Hz
S.C BREAKING CURRENT	26.3 kA RMS
C. MAKING CURRENT	26.5 kA RMS
SHORT TIME CURRENT	
WT	127 kg

Email enquires to
pbpower@pbsi.co.uk

PBSI Registered Office
Belle Vue Works
Boundary Street
Manchester
M12 5NG

T +44 (0)161 223 5151
F +44 (0)161 230 6464