


VCB Retrofit

SOUTH WALES SWITCHGEAR

TYPE D8/12X

OVERVIEW

- Type tested retrofit
- Long life
- Low maintenance
- Long term service support using ABB type VD4 VCB
- Enhanced performance ratings



TECHNICAL DATA	<i>P&B Type tested rating</i>
SYSTEM VOLTS	12 kV
RATED CURRENT	1250 A
FREQUENCY	50 / 60 Hz
S.C BREAKING CURRENT	13.2 kA
C. MAKING CURRENT	33.5 kA PEAK
SHORT TIME CURRENT	13.2 kA 3 sec
WT	270 kg

Email enquires to
pbpower@pbsi.co.uk

PBSI Registered Office
Belle Vue Works
Boundary Street
Manchester
M12 5NG

T +44 (0)161 223 5151
F +44 (0)161 230 6464